AHMEDABAD MUNICIPAL CORPORATION
MAHANAGAR SEVA SADAN

CENTRAL LABORATORY

(An ISO 9001: 2015 Accredited Laboratory)

JAS-ANZ
CPG
Lic No QAC/R91/4650

Dudheshwar Water Works Compound, Dudheshwar, Ahmedabad-380 004, Gujarat, India
E-mail: centrallab@ahmedabadcity.gov.in, Phone No-(079) 25631105, 25630438

June 02, 2025.

To,
The Principal,
Sant Kabir High School, B/h H.L. College of Commerce,
Navarangpura, Ahmedabad - 380009

Dear Sir,

We have analyzed your water samples collected on Dt. 21-05-2025 for the following **Chemical and Bacteriological** parameters. The analysis report is as hereunder.

Sr. No.	Parameter	Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternate Source	Sample Value
		As per IS-10500-2012		
A.	**Organoleptic and Physical Parameters**			
1	Colour, Hazen units, Max	**5**	**15**	0.1
2	pH value	**6.5-8.5**	**No relaxation**	7.2
3	Turbidity, NTU, Max	**1**	**5**	0.1
4	Total dissolved solids, mg/l, Max	**500**	**2000**	126
B.	**General Parameters**			
1	Total hardness (as $CaCO_3$), mg/l, Max	**200**	**600**	20
2	Calcium (as Ca), mg/l, Max	**75**	**200**	4
3	Magnesium (as Mg), mg/l, Max	**30**	**100**	2.44
4	Chloride (as Cl), mg/l, Max	**250**	**1000**	25
5	Sulphate (as SO_4) mg/l, Max	**200**	**400**	8.2
6	Total alkalinity (as $CaCO_3$), mg/l, Max	**200**	**600**	60
7	Free residual chlorine, mg/l, Min	**0.2**	**1.0**	Nil
C.	**Bacteriological Quality of Drinking Water**			
1	Total Coliform bacteria, MPN/100 ml.	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	Not Detectable
2	E. coli, MPN/100 ml	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	Not Detectable

Remarks:

1. The Central Laboratory, AMC, has collected the samples.
2. The result contained in this report relate only to the sample material tested.
3. The report is not being reproduce wholly or in part and cannot be used as evidence in the court of law and should not be used in any advertising media without our special permission in writing.

NOTE — It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned under 'acceptable' render the water not suitable, but still 'permissible limit in the absence of alternate source' in column 4, above which the sources will have to be rejected. May be tolerated in the absence of an alternative source but up to the limits indicated.

Scientist In-Charge
Central Laboratory

Ahmedabad Municipal Corporation

Sr. No. 100

S.W.M. W.Z.

SWM
~~Health~~ Department

SANITARY CONVENIENCE CERTIFICATE

A Certificate for Sanitary Convenience is issued to the Manager / Secretary / Organiser of the Talkies / Theatre namely ST. KABIR HIGH SCHOOL VISHESH V. TANDAN *Situated at* B/H. H. L. college of Commerce, Navrangpura Ahmedabad-9 *for the period of* 12 *months / Days i. e. from* 01/01/26 *200 to* 31/12/26 *200*

Date : 25/2/26

Dy./Add. Medical Officer of Helath
Municipal Corporation Ahmedabad.

By. Director
(S.W.M. West Zone)

"Issued Subject to NOC from other Concemed departments".

Copy to :-
1. The Manager / Secretary
2. The Commissioner of Police Ahmedabad.

Rs. 1000/-
પા.ઇ. 1196/66
25/2/26